



CITY OF CLAREMONT, CALIFORNIA

SEWER REHABILITATION PROJECT – PHASE 2

BID NO. CS-20-04

RFI NO. 1

April 1, 2020

NOTE: THE BIDDER SHALL SIGN AND ATTACH THIS ADDENDUM/REQUEST FOR ADDITIONAL INFORMATION TO THE CONTRACT DOCUMENTS SUBMITTED WITH THE BID.

Requests for Clarification

- Q1. *The bid form shows bid items are not in numeric order, it jumps from 4 to 6 and then 6 to 8. Are there bid items missing or just a mistake in the numbering?***
- A1. This was a clerical error, a revised bid sheet is included as Attachment A.
- Q2. *Bid item #4 states UV CIPP Lining along with the Special Conditions CIPP specification also states UV cure, however the NASSCO CIPP installation document you have also provided covers Standard Water installation and Air Inversion Steam Cure installations. Is the city allowing water and air/steam installations along with UV?***
- A2. The City requires UV CIPP Lining.
- Q3. *Specification state that the Prime Contractor must have 90% of the entire project. State, Greenbook and Industry standards allows for a 50% of the project to be primed by the bidding contractor. Most all the CIPP lining contractors in Southern California do not install CIPP patches. Typically a clean & CCTV sub-contractor installs these for a CIPP lining contractor. We would like to suggest the city change the 90% required to follow the State, Greenbook and Industry standards to allow 50% of the project performed by Prime Contractor.***
- A3. The City requires the prime contractor must complete 90% of the entire project per the bid document.

Q4. This is the email inquiry I have for the value of the above project per our phone conversation earlier.

A4. The engineer's estimate is approximately \$262,000.

Q5. We request the City consider adding Folded and Reformed PVC pipeliner back into the specification for use on this project.

A5. The City requires UV CIPP Lining per the specifications.

Q6. We do not see any plans and/or maps for the pipe rehab locations. Please provide maps and plans for all rehab locations, thank you.

A6. Please refer to Attachment D which details the locations and scope of work. Maps will be made available to the selected bidder.

Submitted by:

Kristin Mikula

Kristin Mikula, Community Services Manager

I hereby acknowledge receipt of this addendum and understand that the changes shown herein are made a part of the contract.

By: _____
Signature of Bidder, Company Name

BID FORM**NAME OF BIDDER:** _____

The undersigned, hereby declare that we have carefully examined the location of the proposed Work, and have read and examined the Contract Documents, including all plans, specifications, and all addenda, if any, for the following Project:

Sewer Rehabilitation Project - Phase 2

We hereby propose to furnish all labor, materials, equipment, tools, transportation, and services, and to discharge all duties and obligations necessary and required to perform and complete the Project for the following TOTAL BID PRICE:

BID SCHEDULE

BID ITEM NO.	DESCRIPTION	QTY	UNIT	UNIT PRICE	SUB TOTAL
1	Mobilization	1	LS		
2	Traffic Control	1	LS		
3	Bypass	1	LS		
4	UV CIPP Lining including Lateral Cutouts	2,932	LF		
5	UV CIPP Patches including Lateral Cutouts	37	EA		
6	Point Repair	1	EA		
Total Bid Price in Numerical Form:					
Total Bid Price in Written Form:					

In case of discrepancy between the unit price and the item cost set forth for a unit basis item, the unit price shall prevail and, shall be utilized as the basis for determining the lowest responsive, responsible bidder.

City shall award the Contractor for the Project to the lowest responsible bidder as determined from the base bid alone.

The undersigned agrees that this Bid Form constitutes a firm offer to the City which cannot be withdrawn for the number of calendar days indicated in the Notice Inviting Bids from and after the bid opening, or until a Contract for the Work is fully executed by the City and a third party, whichever is earlier.

The Contract duration shall commence on the date stated in the City's Notice to Proceed, and shall be completed by the Contractor in the time specified in the Contract Documents. In no case shall the Contractor commence construction prior to the date stated in the City's Notice to Proceed.

Bidder certifies that it is licensed in accordance with the law providing for the registration of Contractors, License No. _____, Expiration Date _____, class of license _____. If the bidder is a joint venture, each member of the joint venture must include the above information.

The undersigned acknowledges receipt, understanding and full consideration of the following addenda to the Contract Documents.

Addenda No. _____

Addenda No. _____

Addenda No. _____

1. Attached is the required bid security in the amount of not less than 10% of the Total Bid Price.
2. Attached is the fully executed Non-Collusion Affidavit form.
3. Attached is the completed Designation of Subcontractors form.
4. Attached is the completed Bidder Information Form.
5. Attached is the completed Contractor's Certificate Regarding Workers' Compensation form.
6. Bidder acknowledges and understands that, pursuant to Public Contract Code Section 20676, sellers of "mined material" must be on an approved list of sellers published pursuant to Public Resources Code Section 2717(b) in order to supply mined material for this Contract.

I hereby certify under penalty of perjury under the laws of the State of California, that all of the information submitted in connection with this Bid and all of the representations made herein are true and correct.

Name of Bidder _____

Signature _____

Name and Title _____

Dated _____