ALPINE COUNTY ENVIRONMENTAL HEALTH WATER QUALITY LOG FACILITY NAME: MANAGER/POOL CARETAKER: **RECOMMENDED CHEMICAL LEVELS:** CHLORINE: 1.0 ppm minimum without chanuric acid. 1.5 ppm with cyanuric acid pH: 7.2 - 8.0; optimum range is 7.4 - 7.6 ALKALINITY: 80 - 120 ppm CALCIUM HARDNESS: 150 - 300 ppm CYANURIC ACID: 100 ppm maximum Water Test and Filter Check Month: Free chlorine Date residual Total alkalinity Calcium Hardness Cyanuric Acid Backwash filters Tester's initials 1 2 3 4 5 6 7 8 9 10 11 12 13 14

15

Water Test and Filter Check						
Month:						
Date	Free chlorine residual	Total alkalinity	Calcium Hardness	Cyanuric Acid	Backwash filters	Tester's initials
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

For further information regarding swimming pool and spa pool regulations, maintenance and pool care, contact the Alpine County Health Department at 530-694-2146.

water quality log updated 01/08/2013