




COUNTY OF LOS ANGELES FIRE DEPARTMENT FIRE PREVENTION DIVISION

REV 04/03

ACCESS STANDARD FOR SINGLE FAMILY RESIDENCES

Water Tank
(if required)



Vehicular Access to within 150 Feet
of all portions of the exterior walls on
the first floor.

Approved Turn Around
May Be Required

PROPOSED
STRUCTURE

Fire Hydrant located within
50 - 150 feet from structure
and 5 feet off driveway.

1' deep
3' by 3'
Concrete
Pad

1. All weather access may require paving.
2. If grades over 10 percent – Paving Mandatory.
3. Paving must be per Fire Department Standards.
4. Tree Limbs – Trim to 13.5 ft. above road bed.
5. Long driveways may require Turnouts and/or Turn-A-Rounds.
6. Driveway may be reduced to 15 ft. when serving not more than two single family dwellings.

Driveway
20 ft.

Approved Address
at Street and House
(5" Letters)

Gates
see Reg.#5

APPROVED STREET NAME

26'

20 FT.WIDE PRIVATE DRIVES



Public Fire Hydrant Must
Meet Required Fire Flow